



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 5/6/26

Location of event: Hot Springs Creek

Sample collection date: 5/11/26

Samples analyzed for: E. Coli

ANALYSIS RESULTS

<u>Site #</u>	<u>Time collected</u>	<u>Results</u>
Site 2:	0941	E. Coli – 410.6 cfu per 100mls
Site 3:	0946	E. Coli – 9.8 cfu per 100mls
Site 4:	0956	E. Coli – 50.4 cfu per 100mls

Testing will continue until two consecutive results are below 126 cfu's per 100 mls at site #2, site #3, and site #4.

Amanda Cates
Laboratory Supervisor

Harold Mauldin
Facilities Operations Manager
City of Hot Springs