



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 6/15/25

Location of event: Hot Springs Creek

Sample collection date: 6/18/25

Samples analyzed for: E. Coli

ANALYSIS RESULTS

<u>Site #</u>	<u>Time collected</u>	<u>Results</u>
Site 2:	0827	E. Coli – 272.3 cfu per 100mls
Site 3:	0834	E. Coli – 9.8 cfu per 100mls
Site 4:	0837	E. Coli – 26.6 cfu per 100mls

Testing will continue until two consecutive results are below 126 cfu's per 100 mls at site #2, site #3, and site #4.

Amanda Cates
Laboratory Supervisor

Harold Mauldin
Facilities Operations Manager
City of Hot Springs