



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 6/15/25

Date and time of notification: 6/16/25 @ 0738

Location of event: Manhole 1754 @ 962 Ridgeway

Sample collection date and time: 6/16/25 @ 0835

Samples analyzed for: E. Coli

ANALYSIS RESULTS

Site 1: E. Coli – 1413.6 cfu per 100mls
(Overflow Location)

Amanda Cates
Laboratory Supervisor

Harold Mauldin
Facilities Operations Manager
City of Hot Springs