



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 6/15/25 & 6/19/25

Location of event: Hot Springs Creek

Sample collection date: 6/24/25

Samples analyzed for: E. Coli

ANALYSIS RESULTS

<u>Site #</u>	<u>Time collected</u>	<u>Results</u>
Site 2:	0912	E. Coli – 59.1 cfu per 100mls
Site 3:	0920	E. Coli – 48.1 cfu per 100mls
Site 4:	0924	E. Coli – 4.1 cfu per 100mls

On 6/24/25 and 6/23/25 test results were below 126 cfu's per 100 mls at site #2, site #3, and site #4. This meets the testing requirements. No further testing is needed.

Amanda Cates
Laboratory Supervisor

Harold Mauldin
Facilities Operations Manager
City of Hot Springs