



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 6/19/25

Location of event: Hot Springs Creek

Date and time of notification: 6/20/25 @ 0659

Sample collection date and time: 6/20/25 @ 0819

Samples analyzed for: E. Coli

ANALYSIS RESULTS

Site 1: E. Coli – 1119.9 cfu per 100mls
(Overflow Location)

This test result is above the EPA recommended 126 cfu's per 100mls at designated Site #1. Testing will continue at site 2, site 3, and site 4 until two consecutive samples are below 126 cfu's per 100mls.

Amanda Cates
Laboratory Supervisor

Harold Mauldin
Facilities Operations Manager
City of Hot Springs