



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 7/2/24

Location of event: Gulpha Creek (Manhole 1750)

Sample collection date: 7/7/24

Samples analyzed for: E. Coli

ANALYSIS RESULTS

<u>Site #</u>	<u>Time collected</u>	<u>Results</u>
Site 3:	1004	E. Coli – 19.7 cfu per 100m
Site 4:	1011	E. Coli – 6.3 cfu per 100mls
Site 5:	1018	E. Coli – 1.0 cfu per 100mls

On 7/3/24 and 7/4/24 results at site #2 were below 126 cfu's per 100mls. On 7/6/24 and 7/7/24 results were below the 126 cfu's per 100 mls at site #3, site #4, and site #5. No further testing is needed.

Amanda Cates
Laboratory Supervisor

Harold Mauldin
Facilities Operations Manager
City of Hot Springs