



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Location of event: Hot Springs Creek

Date of overflow event: 7/9/24

Sample collection date: 7/11/24

Samples analyzed for E. Coli.

ANALYSIS RESULTS

<u>Location</u>	<u>Collection time</u>	<u>Results</u>
Site #2	1203	E. Coli – 9.5 cfu per 100mls
Site #3	1208	E. Coli – 74.8 cfu per 100mls
Site #4	1212	E. Coli – 4.1 cfu per 100mls

On 7/10/24 and 7/11/24 sample results were below 126 cfu's per 100mls at each designated site. No further testing is required.

Amanda Cates
Laboratory Manager

Harold Mauldin
Facilities Operations Manager
City of Hot Springs