



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 7/9/24

Location of event: Gulpha Creek

Sample collection date: 7/12/24

Samples analyzed for: E. Coli

ANALYSIS RESULTS

<u>Site #</u>	<u>Time collected</u>	<u>Results</u>
Site 2:	0937	E. Coli – 44.8 cfu per 100mls
Site 3:	0943	E. Coli – 435.2 cfu per 100m
Site 4:	0948	E. Coli – 13.2 cfu per 100mls
Site 5:	0954	E. Coli – 28.8 cfu per 100mls

Testing will continue until two consecutive results are below the 126 cfu's per 100 mls at site #2, site #3, site #4, and site #5.

Tina Mietzner
Laboratory Technician

Harold Mauldin
Facilities Operations Manager
City of Hot Springs