



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 7/9/24

Location of event: Gulpha Creek

Sample collection date: 7/15/24

Samples analyzed for: E. Coli

ANALYSIS RESULTS

<u>Site #</u>	<u>Time collected</u>	<u>Results</u>
Site 3:	0956	E. Coli – 167.0 cfu per 100m
Site 4:	1000	E. Coli – 14.5 cfu per 100mls
Site 5:	1006	E. Coli – 48.7 cfu per 100mls

On 7/11/24 and 7/12/24 test results were below 126 cfu's at site #2. Testing will continue until two consecutive results are below 126 cfu's per 100 mls at site #3, site #4, and site #5.

Amanda Cates
Laboratory Supervisor

Harold Mauldin
Facilities Operations Manager
City of Hot Springs