



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 9/12/25

Date and time of notification: 9/12/25 @ 1443

Location of event: Gulpha Creek

Sample collection date and time: 9/12/25 @ 1621

Samples analyzed for: E. Coli

ANALYSIS RESULTS

Site 1: E. Coli – 19.9 cfu per 100mls
(Overflow Location)

This test result is below the EPA recommended 126 cfu's per 100mls at designated Site #1. No further testing is required at this time.

Tina Mietzner
Laboratory Technician

Harold Mauldin
Facilities Operations Manager
City of Hot Springs