



# CITY OF HOT SPRINGS

## Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

### SSO ANALYSIS REPORT

Date of overflow event: 5/6/25

Date and time of notification: 5/7/25 @ 0600

Location of event: Gulpha Creek

Sample collection date and time: 5/7/25 @ 0743

Samples analyzed for: E. Coli

#### ANALYSIS RESULTS

Site 1: E. Coli – 770.1 cfu per 100mls  
(Overflow Location)

This test result is above the EPA recommended 126 cfu's per 100mls at designated Site #1. Testing will continue until two consecutive test results are below 126 cfu's at site #2, site #3, site #4, and site #5.

Amanda Cates  
Laboratory Supervisor

Harold Mauldin  
Facilities Operations Manager  
City of Hot Springs