



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 5/6/25

Location of event: Hot Springs Creek

Sample collection date: 5/12//25

Samples analyzed for: E. Coli

ANALYSIS RESULTS

<u>Site #</u>	<u>Time collected</u>	<u>Results</u>
Site 2:	0849	E. Coli – 28.8 cfu per 100mls
Site 3:	0858	E. Coli – 12.1 cfu per 100mls
Site 4:	0906	E. Coli – 7.5 cfu per 100mls

On 5/9/25 and 5/12/25 test results were below 126 cfu's per 100 mls at site #2, site #3, and site #4.
No further testing is required at this time.

Amanda Cates
Laboratory Supervisor

Harold Mauldin
Facilities Operations Manager
City of Hot Springs