

Amanda Blackmon (adpce.ad)

From: Shawn Davis <SDavis@cityhs.net>
Sent: Friday, June 20, 2025 2:25 PM
To: Amanda Blackmon (adpce.ad); Bobby Harris; Eric Skinner (Eric.Skinner@adeq.state.ar.us); Harold Mauldin; Howard Hoover; Jason Bolenbaugh (adpce.ad); Jimmy Davis; Kristen Graham; Leslie Allen-Daniel (adpce.ad); Monty Ledbetter; Shawn Davis
Subject: SSO Stoppage

Hot Springs Wastewater
Permit # AR0033880

Reference #6141eb8a-e643-43c2-a992-fc066597e7c2
Address: 857 Carpenter Dam Rd
Manhole #5259
Start: 6/19/2025 @ 1:00 pm
End: 6/20/2025 @ 1:00 pm
Cause: Rain, Equipment Failure
Creek: Unknown
Volume: 216,000
Clean Up: Hydro, Environmental, Raked & Picked Up Debris, Spread Lime