

Amanda Blackmon (adpce.ad)

From: Shawn Davis <SDavis@cityhs.net>
Sent: Tuesday, June 17, 2025 8:17 AM
To: Amanda Blackmon (adpce.ad); Bobby Harris; Eric Skinner (Eric.Skinner@adeq.state.ar.us); Harold Mauldin; Howard Hoover; Jason Bolenbaugh (adpce.ad); Jimmy Davis; Kristen Graham; Leslie Allen-Daniel (adpce.ad); Monty Ledbetter; Shawn Davis
Subject: SSO Stoppage

Hot Springs Wastewater
Permit # AR0033880

Reference # [7f478a95-50db-42fa-8ea3-7dfb60155cf3](#)

Address: 3044 Malvern Ave

Manhole # 1748

Start: 6/15/2025 @ 7:30 pm

End: 6/17/2025 @ 2:30 am

Cause: Rain, Equipment Failure

Creek: Gulpha

Volume: 418,500

Clean Up: Hydro, Jet-Vac, Environmental, Raked & Picked Up Debris, Spread Lime

Reference # [c17072ed-77d4-4ca9-bba0-f0c9b26bc074](#)

Address: 857 Carpenter Dam Rd

Manhole # 5259

Start: 6/15/2025 @ 8:00 pm

End: 6/17/2025 @ 1:00 am

Cause: RAIN, Equipment Failure

Creek: Unknown

Volume: 348,000

Clean Up: Hydro, Environmental, Raked & Picked Up Debris, Spread Lime