

Amanda Blackmon (adpce.ad)

From: Shawn Davis <SDavis@hotspringsar.gov>
Sent: Tuesday, February 17, 2026 1:23 PM
To: Amanda Blackmon (adpce.ad); Bobby Harris; Eric Skinner (Eric.Skinner@adeq.state.ar.us); Gregg Asher; Harold Mauldin; Howard Hoover; Jason Bolenbaugh (adpce.ad); Jesse McDorman; Jimmy Davis; Kristen Graham; Leslie Allen-Daniel (adpce.ad); Monty Ledbetter; Shawn Davis
Subject: SSO Stoppages

Hot Springs Wastewater
Permit # AR00338800

Reference # [2d03175e-e234-43d1-80f5-f595b725f763](#)
Address: 362 Fontana Rd.
Lift Station =Bar Screen
Start: 2/16/2026 @ 9:00 am
End: 2/16/2026 @ 11:00 pm
Cause: Equipment Failure
Creek: Hot Springs
Volume: 378,000
Clean Up: Hydro, Jet-Vac, Environmental, Raked & Picked Up Debris, Spread Lime

Reference # [08e25f5e-9258-41ea-a368-fdb1ea1f8bf7](#)
Address: 107 Forest View Ct.
Manhole # 3728
Start: 2/16/2026 @ 9:30 am
End: 2/16/2025 @ 9:30 pm
Cause: Equipment Failure
Creek: Unknown
Volume: 72,000
Clean Up: Hydro, Environmental, Picked Up Debris, Spread Lime