

Amanda Blackmon (adpce.ad)

From: Shawn Davis <SDavis@hotspringsar.gov>
Sent: Monday, March 9, 2026 10:33 AM
To: Amanda Blackmon (adpce.ad); Bobby Harris; Eric Skinner (Eric.Skinner@adeq.state.ar.us); Gregg Asher; Harold Mauldin; Howard Hoover; Jason Bolenbaugh (adpce.ad); Jesse McDorman; Jimmy Davis; Kristen Graham; Leslie Allen-Daniel (adpce.ad); Monty Ledbetter; Shawn Davis
Subject: SSO Stoppage

EXTERNAL SENDER: This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Hot Springs Wastewater
Permit # AR0033880

Reference #c2e314fe-fd7f-4a39-8056-6d9c1be2ca1c
362 Fontana Rd.
Manhole # 1866
Start: 3/7/2026 @ 7:30 am
End: 3/9/2026 @ 6:00 am
Cause: Rain , Equipment Failure
Creek: Hot Springs
Volume: 697,500
Clean Up: Hydro, Jet-Vac, Environmental, Raked & Picked Up Debris, Spread Lime

Reference #4cef7926-d8c2-4a6a-2885-7b4b2316bbef
352 Fontana Rd.
Manhole # 1865
Start: 3/7/2026 @ 7:30 am
End: 3/9/2026 @ 6:00 am
Cause: Rain, Equipment Failure
Creek: Hot Springs
Volume: 558,000
Clean Up: Hydro, Environmental, Raked & Picked Up Debris, Spread Lime

Reference #edd7afad-462f-4e06-bfce-6617794e7bdc
857 Carpenter Dam Rd.
Manhole # 5259
Start: 3/7/2026 @ 7:45 am
End: 3/9/2026 @ 6:00 am
Cause: Rain, Equipment Failure
Creek: Unknown
Volume: 624,375
Clean Up: Hydro, Environmental, Raked & Picked Up Debris, Spread Lime