

Leslie Allen-Daniel (adpce.ad)

From: Todd Beaver <toddbeaver@RWU.ORG>
Sent: Wednesday, September 24, 2025 10:20 AM
To: ssoadeq@adeq.state.ar.us
Cc: David Staib; Brent Dobler; Patrick Pruitt
Subject: ar0043397 EQ basin overflow 9-23-25

Follow Up Flag: Follow up
Flag Status: Flagged

Please accept this email as our required 24-hour notification of an overflow at the treatment facility. The Rogers area received over 11 inches of rain in 7 days. This rain event caused our equalization basin to begin overflowing at 6:28 PM. The overflow stopped at 2:18 AM with 1.7 MG having overflowed. We collected samples for testing per our SOP.

Sincerely,

Todd Beaver, P.E.
Plant Manager
479-273-7378 ext. 6550

***Please note: Our email domain has changed. My new email address is ToddBeaver@RWU.org**



ROGERS WATER UTILITIES (RWU) CONFIDENTIALITY NOTICE - THIS ELECTRONIC MAIL TRANSMISSION AND ANY DOCUMENTS ACCOMPANYING IT MAY CONTAIN CONFIDENTIAL INFORMATION CONCERNING RWU AND ITS CUSTOMERS THAT IS PROTECTED FROM DISCLOSURE BY THE ARKANSAS FREEDOM OF INFORMATION ACT (FOIA), CODIFIED AT ARK CODE ANN. § 25-19-101 ET SEQ. AND OTHER APPLICABLE LAW. THE INFORMATION IS INTENDED ONLY FOR THE USE OF THE PERSON TO WHOM IT IS ADDRESSED. IF YOU HAVE RECEIVED THIS TRANSMISSION IN ERROR, PLEASE IMMEDIATELY NOTIFY THE SENDER TO ARRANGE FOR THE RETURN OF THE MESSAGE AND ANY ATTACHED DOCUMENTS. NOTHING IN THIS ELECTRONIC MAIL TRANSMISSION AND THE ACCOMPANY DOCUMENTS SHALL BE CONSTRUED AS A WAIVER, LIMIT, MODIFICATION, NULLIFICATION, OR ALTERATION OF THE TORT IMMUNITY AND OTHER RIGHTS AND IMMUNITIES GRANTED TO RWU, THE ROGERS WATERWORKS AND SEWER COMMISSION, AND THE CITY OF ROGERS, ARKANSAS PURSUANT TO ARK CODE ANN. § 21-9-301 AND OTHER APPLICABLE LAW.