

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0048691 Discharge Number: 001-A

Facility: TEXARKANA, CITYOF-NORTH WWTP

Address: 8301 Sanderson Lane

City: Texarkana State: AR Zip: 71854

Contact: Gary Smith, Executive Director Phone: 903-798-3821

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
January 2024	Effluent Flow	1.361		<=0.95 Daily Max
January 2024	Sulfate	647.67		<=480.0 MO AVG

We feel this problem was due to:

Heavy rainfall for several days caused High average Sulfate and High Effluent Flow


We plan on correcting the problem in this manner:

N/A

Time estimated that it will take to correct problem:

N/A

Sincerely,


Submitted By:

6-24-2024
Date

☐ Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)