

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0051951 Discharge Number: 001
Facility: Tupelo Bayou WWTP
Address: 1405 Lollie Rd
City: Conway State: AR Zip: 72034
Contact: Lee Tedford Phone: (501) 548-3041

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
6-24-2024 thru 6-28-2024	Fecal Coliform		891 #/100mL	≤ 400 #/100mL

We feel this problem was due to:

New industry (Westrock Coffee) dumped a strong
solution of dairy product into wastewater
stream and UV disinfection was ineffective

We plan on correcting the problem in this manner:

Working with Garver to determine solution.
Taking samples per Garver for analysis

Time estimated that it will take to correct problem:

1 month

Sincerely,

Lee Tedford

Submitted By:

7/17/2024

Date

☐ Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)