

# ADEQ

ARKANSAS  
Department of Environmental Quality

JUN 14 2017

Paul Colvin, Mayor  
City of Tontitown  
PO Box 305  
Tontitown, AR 72770

RE: 2016 Annual Report Submission, City of Tontitown  
Small Municipal Separate Storm Sewer Systems General Permit ARR040000  
Tracking Number **ARR040049**, AFIN **72-02164**

Dear Mr. Colvin,

The 2016 annual report required by Part 4.3 of the Small Municipal Separate Storm Sewer Systems (MS4) General Permit ARR040000 was received and reviewed.

Please be aware that, per Part 3.2.3.2 of the permit, a completed storm sewer map of the entire MS4 system, including catch basins, pipes ditches, and stormwater facilities shall be completed within five years of when permit coverage was initially granted (August 19, 2018).

Additionally, per Part 3.2.3.9 of the permit, the permittee shall include dry-weather screening of all stormwater outfalls located in the MS4's urbanized area at the time of this permit coverage over the permit term. Based on a review of previous annual reports, the permittee has not made any efforts to complete this requirement.

It should be of note that Part 3.2.6.4 of the permit states, "Annual inspections for all municipal facilities not requiring industrial stormwater permit coverage are required for municipal facilities performing maintenance activities on mechanical equipment, facilities with fueling stations, facilities involved in waste storage, transfer or recycling, facilities with material stockpiles, and facilities storing fertilizers or pesticides." Based on the information provided in the annual report, this requirement was not met in 2016.

If you have any questions concerning this matter or need additional information, please feel free to contact me at (501) 682-0626 or at [ahrendsen@adeq.state.ar.us](mailto:ahrendsen@adeq.state.ar.us).

Sincerely,



Blake Ahrendsen  
NPDES Engineer  
Office of Water Quality