RELEASE PREVENTION (Cont'd)

Facility ID#: 60000135

Check (√) for compliance; "No" for noncompliance. Leave blank for "N/A".

IV. CORROSION PROTECTION	System# 2		System# 3		System# 4		System#	
A. Material of Construction (Check all that apply)	Tank	Piping	Tank	Piping	Tank	Piping	Tank	Piping
NON-CORRODIBLE	✔	✔	✔	✔	✔	✔		
CORRODIBLE								
B. Internal lining								
(1) Installed according to a recommended practice.								
(2) Inspected in a timely manner and lining is in compliance. [7]								
(3) Inspected according to approved protocol.								
(4) Corrective action taken on failed inspection.								
C. Galvanic (sacrificial) anodes								
(1) Designed by CP expert/specialist.								
(2) Tested in a timely manner.								
(3) Corrective action taken on failed test.								
(4) Metal components (i.e., flex lines, subpumps, etc.) protected as required. [8]								
(5) Operational records available.								
D. Impressed current								
(1) Designed by CP expert/specialist.								
(2) Tested in a timely manner.								
(3) Rectifier is operational.								
(4) Verify records of 60 day check. [6]								
(5) Corrective action taken on failed check.								
(6) Operational records available.								
(7) CP system maintained.								
(8) Metal components (i.e., flex lines, subpumps, etc.) protected as required. [8]								

Comments:

Inspector's Signature Signed with SignDoc Signed on 2008-05-15 9:32:26 Date May 13, 2008