

January 16, 2026

Mr. Bryan Leamons
5301 Northshore Drive
North Little Rock, AR 72118

RE: NOTICE OF VIOLATION – FAILURE TO MONITOR

Dear Mr. Leamons:

The City of Springfield industrial pretreatment permit #593 issued to Nabors Landfill requires semi-annual pH monitoring. The semi-annual sampling field pH parameter was not sampled during the July 1, 2025, to December 31, 2025, reporting period. This is a failure to monitor violation of the permit.

As detailed in Part 2, Monitoring Requirements of the permit, Nabors Landfill is to ensure that pH is monitored semi-annually. Wastewater pH shall be analyzed on site within 15 minutes of collecting grab samples using 40 CFR 136 approved testing methods. It is highly recommended to annotate the field pH on the chain of custody sample form at time of sampling.

If you should have any questions concerning these matters, please contact me at (417) 864-1487.

Sincerely,

**CITY OF SPRINGFIELD
ENVIRONMENTAL SERVICES**



Liz Mack
Senior Environmental Compliance Specialist

Clean Water Operations
755 N. Franklin Ave. • Springfield, Missouri 65802-4121
(417) 864-1544 • www.springfieldmo.gov



**CITY OF
Springfield
ENVIRONMENTAL
SERVICES**