Underground Storage Tanks (USTs) Public Record

General Information

Public Record Posted Date: 11/4/26

Total Number Of Active UST Facilities: 2953
Total Number Of Active USTs: 7493

Summary Information For On-Site Inspections

Number Of UST Facilities Inspected: 1420
Inspection Period Dates: 10/1/25 To: 9/30/26
Percent Compliance (Technical Compliance Rate Measure): 54.57%

Note: Compliance rate is based on the combined performance measures indicated for technical compliance rate with state and Federal UST requirements.

Summary Information For Release

Number Of Confirmed UST Releases: 29
Release Reporting Period Dates: 10/1/25 to 9/30/26

Summary Information For Release Sources And Causes

Source			Cause													
			Spill		Overfill		Phys/Mech Damage		Corrosion		Install Problem		Other		Unknown	
	#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%
Tank	2	7%													2	100%
Piping	6	21%					3	50%							3	50%
Dispenser	0	0%													0	0%
STP	4	14%							2	50%					2	50%
Delivery Problem	0	0%													0	0%
Other	1	3%													1	100%
Unknown (Optional)	16	55%													16	100%
Totals	29	100%					3	10%	2	7%					24	83%

"Unknown" is based on an unidentifiable source or cause of release.
"Other" is an identifiable source or cause of release that does not fit specific locations identified in the chart.